

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-RA5009

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

'Flameshield Roller Shutter'

Product: Fire resisting roller shutter covered by EN 13241

Intended use: Fire compartmentation and/or escape routes

Essential characteristics	Performance	Harmonised technical specification
Resistance to Fire ¹	E60 / E120 / E240	EN 16034:2014
Smoke control (only for applications where limitation of smoke spread is required)	NPD	
Ability to release ²	released	
Self Closing (only for self closing fire resistance and/or smoke control doorsets and/or openable windows) ³	C	
Durability of ability to release	NPD	
Durability of self-closing	NPD	

The following documentation has been used in support of the essential characteristics performance stated above:

1. EXAP referenced WF Report No. 422881 (Issue 2), Classification referenced WF Report No. 422883 (Issue 3)
2. Test referenced WF Report No. 421378 and WF Report No. 421972,
3. Test referenced WF Report No. 421378 and WF Report No. 421972, Classification referenced WF Report No. 422883 (Issue 3)

Certificate of Constancy of Performance

2812-CPR-RA5009

Placed on the market under the name of

**A1 Shutters Limited
Jackson Works
Raikes Lane Industrial Estate
Bolton
BL3 2NH
United Kingdom**

and produced in the manufacturing plant

E/346

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 16034: 2014

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **14/12/2020** and reissued on **24/04/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

CE Marking certificate valid to: **23/04/2026**

ERO Project Reference: **ERO 034621 P1994**



Paul Duggan
Certification Manager

CSF408-NL 7.0